



UROX.S25212 Smoke-automatic Fire Detectors

[Page Bottom](#)

Smoke-automatic Fire Detectors

[See General Information for Smoke-automatic Fire Detectors](#)

NINGBO AMBEST ELECTRONICS CO LTD

S25212

#70 HUANGSU RD(W)
INDUSTRIAL ZONE OF DONGQIANHU
TOURIST RESORT DISTRICT
NINGBO, ZHEJIANG 315121 CHINA

Detector	Application	Type	Compatibility Restrictions	Velocity Range (fpm)		Date of Manufacture	Time of Manufacture Firmware Version	Firmware Version Update
				Min	Max			
SNC-300-CR	OAP, RS	P(IHD)	D4	0	300	-	-	-
SNC-300-SR	OAP, RS	P	D4	0	300	-	-	-

Base Model	Related Detector	Control Unit Compatibility Restrictions
CN3021	SNC-300-S2, SNC-300-C2	B1
CN3041	SNC-300-SR, SNC-300-CR, SNC-300-SL, SNC-300-CL	B1

B1 - Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

D4 - For connection to any manufacturer's Listed compatible control unit.

OAP - Open Area Protection

RS - Releasing Service

P - Photoelectric

IHD - Includes Integral Heat Detector

Date of Manufacture identifies the manufacturing start date of all product models that will use the specific Time of Manufacture Firmware Version. The date of manufacture is noncoded and in the format YEAR (in 4 digits), MONTH (in letters), DAY (in 2 digits).

Time of Manufacture Firmware Version identifies a numerical and/or alphabetic series designation that is product and date-code specific and will only identify the Firmware Version at the time the product was manufactured. The numeric and/or alphabetic sequence is defined by the manufacturer.

Firmware Version Update is a numerical and/or alphabetic sequential identification that is product and date-code specific and sequentially identifies the Firmware Version Update from the previous version of firmware. The numerical and/or alphabetic sequence is defined by the manufacturer.

Trademark and/or Tradename: 

[Last Updated](#) on 2015-07-15

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)



UROX2.S25212 Smoke-automatic Fire Detectors - Component

[Page Bottom](#)

Smoke-automatic Fire Detectors - Component

[See General Information for Smoke-automatic Fire Detectors - Component](#)**NINGBO AMBEST ELECTRONICS CO LTD**

S25212

#70 HUANGSU RD(W)
INDUSTRIAL ZONE OF DONGQIANHU
TOURIST RESORT DISTRICT
NINGBO, ZHEJIANG 315121 CHINA



Detector Model	Application	Type	Compatibility Restrictions	Velocity Range (fpm)	
				Min	Max
SNC-300-C2, SNC-300-CL	OAP	P(IHD)	D5	0	300
SNC-300-S2, SNC-300-SL	OAP	P	D5	0	300

D5 - For use only with Listed control units with which compatibility was determined by test.

OAP - Open Area Protection

P - Photoelectric

IHD - Includes Integral Heat Detector

Marking: Company name or trademark , model designation, and Recognized Component Mark, .
[Last Updated](#) on 2013-03-25

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2015 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".